



ADDENDUM NO. 1

**Orchard View School District
Cardinal Elementary Parking Lot Restoration
Muskegon, MI**

Date: March 4, 2024

Page 1 of 1

TO ALL BIDDERS:

This **ADDENDUM** is hereby included in and made part of the Contract Documents whether or not attached thereto. All requirements of the original Specifications and Drawings shall remain in force except as noted by this **ADDENDUM No. 1**.

THE PURPOSE OF THIS ADDENDUM IS TO CHANGE THE FOLLOWING ITEMS IN THE CONSTRUCTION DOCUMENTS:

GENERAL

1. Refer to Sheet A-102, detail 3
 - a. Provide a valley gutter in lieu of a curb along the entire west side of the drive access to the stadium.
 - b. Provide 3 cubic yards of MDOT Plain Rip-Rap to stabilize soil on hill side
2. Refer to Sheet A-101
 - a. There is a general note referencing low spots at the end of the existing islands. These areas shall receive a new subbase and asphalt per detail 2/A-103. Other low spots exist throughout the parking area. Contractor shall carry an allowance for replacing 900SF of low spots per detail 2/A-103.

ATTACHMENTS

None

END OF ADDENDUM NO. 1